



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOGMC/2024/00055706
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOGMC/2024/00055706/R1

Date: 22/05/2024

Building Occupancy/Category: Educational (non-residential)

To,

SHASTRI RAMKRISHNADAS SWAMI
SHREE SWAMINARAYAN GURUKUL CAMPUS AHMEDABAD-AIRPORT HIGHWAY NR. EDI AND SARDAR PATEL RING
ROAD CIRCLE BHAT BHAT GANDHINAGAR Gandhinagar MC 382428
Fire Region: Gandhinagar MC.
Mobile No: 9173416091 Email ID: ramswami1974@gmail.com

This has reference to your Application No.2024/00056197 dated 15/05/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise SHREE SWAMINARAYAN INSTITUTE OF TECHNOLOGY (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: 83
4. Village Name: GANDHINAGAR
5. Name of Block(s): A

The building/premise was inspected on 22/05/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 22/05/2024
2. Six monthly inspection was done on 22/05/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 22/05/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Valand Dishant Sunilkumar
Fire Safety Officer - General (FSO-G)
2021/001019

Date: 22/05/2024

Time: 01:49 PM



FSCA/O/CFOGMC/2024/00055706/R1

is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, in the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

use note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, ity shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.





Digitally Verified

Digitally verified by: Valand Dishant Sunilkumar
Fire Safety Officer - General (FSO-G)
2021/001019

Date: 22/05/2024
Time: 01:49 PM



FSCA/O/CFOGMC/2024/00055706/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

